
NTC Reduction: 15th May 2024



Interconnector Net Transfer Capacity Reductions

Ireland

This report is published within 5 working days after the day on which a reduction in Net Transfer Capacity (NTC) has been applied by the System Operator, pursuant to Section 6 of the SEMC Decision Paper on Compensation Arrangements for Net Transfer Capacity Reductions, SEM-24-025 of 28 March 2024 (link).

It is anticipated that the content of the report will evolve over the next months as the various actions in the SEMC decision are implemented.

Disclaimer:
While reasonable care and precaution has been taken to ensure its accuracy, this report and the information contained herein is provided without warranties or representations of any kind with respect to (without limitation) its quality, accuracy, and completeness. All information contained herein is subject to change without notice.

EirGrid (as Transmission System Operator for Ireland) takes no responsibility for any inaccuracies, errors or omissions in this report, and excludes to the fullest extent permitted by law liability for any loss or damage arising from use of this report or reliance on the information contained herein. Any actions taken on foot of this report and the information contained herein are taken at the user's sole risk and discretion, and parties are advised to seek separate and independent opinion in relation to matters covered by this report.

EirGrid

The Oval, 160 Shelbourne Road, Ballsbridge, Dublin D04 FW28
Telephone: +353 1 677 1700 | www.eirgrid.ie

NTC reductions

Reductions in EWIC NTC (from rated capacity of 526 MW) for each hour of the day reported is shown below, together with the reasons for reducing the NTC.

Wednesday 15 May 2024

Hourly NTC reductions: **System Security**

Time (XX:00)	23	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22
MW	0	0	0	0	0	0	0	0	0	89	61	0	0	0	0	0	0	32	154	226	526	526	526	526

Contributing factors (forecast)	Yes (•)	Additional information / reasons
Demand		*Normal seasonal profile*
Renewable generation (Wind/PV)	•	Low forecast for morning peak, very low forecast for evening peak
Plant availability (Conventional/BESS/DSU/TEG)		A number of smaller units unavailable
Long notice units		*No units on long notice*
Energy-limited units (Hydro/DSU/BESS)		*DSU & batteries were considered in the margin over morning and evening peaks*
Transmission constraint		*No transmission constraints*
Support from Northern Ireland	•	Very low support available at morning peak and no support available at evening peak
TEG availability		*TEG units were available*
Testing		*Units on test were not considered for margin purposes*
Other		*n/a*
System State after NTC reductions		**Alert State** was anticipated from 19:30 until 23:00

ENDS.