
NTC Reduction: 11th July 2024



Interconnector Net Transfer Capacity Reductions

Ireland

This report is published within 5 working days after the day on which a reduction in Net Transfer Capacity (NTC) has been applied by the System Operator, pursuant to Section 6 of the SEMC Decision Paper on Compensation Arrangements for Net Transfer Capacity Reductions, SEM-24-025 of 28 March 2024 (link).

It is anticipated that the content of the report will evolve over the next months as the various actions in the SEMC decision are implemented.

Disclaimer:
While reasonable care and precaution has been taken to ensure its accuracy, this report and the information contained herein is provided without warranties or representations of any kind with respect to (without limitation) its quality, accuracy, and completeness. All information contained herein is subject to change without notice.

EirGrid (as Transmission System Operator for Ireland) takes no responsibility for any inaccuracies, errors or omissions in this report, and excludes to the fullest extent permitted by law liability for any loss or damage arising from use of this report or reliance on the information contained herein. Any actions taken on foot of this report and the information contained herein are taken at the user's sole risk and discretion, and parties are advised to seek separate and independent opinion in relation to matters covered by this report.

EirGrid

The Oval, 160 Shelbourne Road, Ballsbridge, Dublin D04 FW28
Telephone: +353 1 677 1700 | www.eirgrid.ie

NTC reductions

Reductions in EWIC NTC (from rated capacity of 526 MW) for each hour of the day reported is shown below, together with the reasons for reducing the NTC.

Thursday 11th July 2024

Hourly NTC reductions: **System Security**

Time (XX:00)	23	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22
MW	0	0	0	0	0	0	0	0	145	283	192	211	192	145	79	0	0	0	0	0	0	0	0	0

Contributing factors (forecast)	Yes (•)	Additional information / reasons
Demand		*Normal seasonal profile*
Renewable generation (Wind/PV)		*Medium forecast for morning and evening peaks*
Plant availability (Conventional/BESS/DSU/TEG)	•	3 large units and a number of smaller units unavailable
Long notice units	•	1 large unit on long notice, assumed available in the evening
Energy-limited units (Hydro/DSU/BESS)	•	DSU & batteries were considered in the margin over morning peak
Transmission constraint	•	Small constraint on generation due to transmission outages in the midlands
Support from Northern Ireland	•	No support available at morning and evening peaks
TEG availability		*2 Operational TEG units available*
Testing		*Units on test were not considered for margin purposes*
Other		*N/A*
System State after NTC reductions		*Normal State was anticipated throughout the day*

ENDS.