Other System Charges (OSC) Trip Report
2024/2025

Date	Unit	MW Lost	Pre-incident [Hz]	Frequency Nadir [Hz]	Trip Type
11/03/2025 01:36	Synergen Power Ltd unit DB1	114		49.87	Fast Wind-down Trip
13/04/2025 03:48	Synergen Power Ltd unit DB1	239.34		49.8	Fast Wind-down Trip
15/04/2025 12:24	ESB Power Generation unit AD2	436.74		49.73	Direct Trip
12/05/2025 13:15	ESB Power Generation	437.66		49.76	Fast Wind-down Trip
11/06/2025 12:35	Synergen Power Ltd	210.04		49.94	Direct Trip
11/06/2025 13:45	ESB Power Generation	146.39		50.00	Direct Trip
19/09/2025 05:47	Energia Power Generation Ltd	241.49		49.87	Direct Trip