Other System Charges (OSC) Trip Report
2025/2026

Date	Unit	MW Lost	Pre-incident [Hz]	Frequency Nadir [Hz]	Trip Type
21/11/2025 21:04	Huntstown Power Co Ltd unit HNC	163.66		49.89	Direct Trip
09/12/2025 16:46	Synergen Power Ltd unit DB1	254.28		49.76	Fast Wind-down Trip
10/12/2025 14:11	SSE Generation Ireland Ltd unit GI4	223.08		49.82	Direct Trip
11/12/2025 20:29	Tynagh Energy Limited unit TYC	226.39		49.83	Fast Wind-down Trip
12/12/2025 08:46	Synergen Power Ltd unit DB1	413.17		49.76	Fast Wind-down Trip
13/12/2025 00:28	SSE Generation Ireland Ltd unit GI4	176.79		49.85	Direct Trip
16/12/2025 18:54	ESB Power Generation unit AD2	430.23		49.79	Direct Trip
20/12/2025 08:42	Synergen Power Ltd unit DB1	117.24		49.9	Fast Wind-down Trip
26/12/2025 11:39	Synergen Power Ltd unit DB1	422.73		49.76	Fast Wind-down Trip
31/12/2025 16:37	Synergen Power Ltd unit DB1	415.26		49.76	Fast Wind-down Trip
04/02/2026 00:16	SSE Generation Ireland Ltd unit GI4	173.08		49.83	Direct Trip
12/02/2026 21:38	Huntstown Power Co Ltd unit HNC	280.95		49.8	Direct Trip
06/03/2026 18:02	Edenderry Power unit ED1	109.42		49.90	Direct Trip
13/04/2026 21:37	Bord Gais Energy Ltd unit WG1	218.73		49.84	Direct Trip
24/05/2026 18:24	Tynagh Energy Limited unit TYC	359.67		49.75	Direct Trip
09/07/2026 17:52	Huntstown Power Co Ltd unit HNC	125.49		49.87	Direct Trip
27/07/2026 14:24	Huntstown Power Co Ltd unit HNC	157.2		49.87	Direct Trip
10/08/2026 13:14	ESB Power Generation unit AD2	133.65		49.85	Direct Trip
22/08/2026 00:28	Energia Power Generation Ltd unit HN2	276.21		49.80	Direct Trip
09/09/2026 01:35	Bord Gais Energy Ltd unit WG1	186.51		49.84	Direct Trip